

Report VGB-TW805e

## Centralized Reliability and Events Database

### Reliability Data for Nuclear Power Plant Components

(Basis edition and enclosed 1st and 2nd upgrading)

#### Description

The Centralized Reliability and Events Database (ZEDB) provides reliability data that can be used in probabilistic safety analyses (PSAs) conducted by the owners/ operators of nuclear power plants. Therefore, the database gathers and analyzes operating experience gained at a large number of nuclear power plants. The main focus is on mechanical and electrical components. The ZEDB use the two-stage Bayesian models to calculate plant-specific and generic reliability data. The analyses are performed for multitude of component populations created for following component prototypes: valves, pumps, fans/ compressors, emergency diesel generators, batteries, rotating inverters, static converters, transformers, busbars, circuit breakers, vessels/ tanks, heat exchangers, and control assembly/ control rods.



The publication provides the results of these analyzes. In addition to the tables of results, including characterization of components population, generic and plant-specific values (5% quantile, 50% quantile (median) and 95% quantile, k factor, mean value), the report contains also an overview of the ZEDB and the method of analysis.

As of December 2006, the format used for publishing the ZEDB analysis results has been changed over to the loose-leaf compilation presented here. Now it is possible to update the analysis results to incorporate new operating experience and to expand the scope of analyzed components by supplying loose-leaf sheets to replace or supplement the previous contents, without having to publish the entire data book again.

The published bundle of several reports (TW 805e) already includes the basis edition (December 2006), the 1st upgrading (December 2007), and the 2nd upgrading (December 2008).

#### Contents

##### Revision Sheet

##### List of Abbreviations

##### 1 Introduction

##### 2 General Description of ZEDB Database

2.1 Background/Objectives

2.2 Organization

2.3 Terms and Definitions

2.1 Database Elements

2.2 Data Acquisition Using ZEDB 2000

2.3 Analytical Capabilities of ZEDB Database

2.4 Structure of Documentation

##### 3 Data Content of ZEDB Database

3.1 Data Acquisition and Quality Assurance

3.2 Component Master Data

3.3 Event Reports

3.4 Operating Reports

3.5 Component Boundaries

##### 4 Theoretical Principles

4.1 The Superpopulation Approach for Estimating Failure Data

4.2 Mathematical Principles of BAYES Program in ZEDB Database

4.3 Utilization of Obtained Reliability Data

## Centralized Reliability and Events Database

### Reliability Data for Nuclear Power Plant Components

(Basis edition and enclosed 1st and 2nd upgrading)

#### Contents *(continued)*

#### **5 Creation of Component Populations**

- 5.1 Basic Procedure
- 5.2 Creation of Populations for Component Prototypes
  - 5.2.1 Valve
  - 5.2.2 Pump
  - 5.2.3 Fans
  - 5.2.4 Emergency Diesel Generator
  - 5.2.5 Vessel / Tank
  - 5.2.6 Heat Exchanger
  - 5.2.7 Control Assembly / Control Rod
  - 5.2.8 Battery
  - 5.2.9 Rotating Inverter
  - 5.2.10 Static Converter
  - 5.2.11 Transformer
  - 5.2.12 Busbar
  - 5.2.13 Circuit Breaker

#### **6 Instructions for Use**

- 6.1 Data Tables
- 6.2 Integration of Drive Control Interfaces and Priority Control Modules
  - 6.2.1 Failure Rates of Drive Control Interfaces and Priority Control Modules
  - 6.2.2 Methodology to Account for Drive Control Interfaces and Priority Control Modules Inside ZEDB Component Boundaries
  - 6.2.3 Simplified Procedure to Account for Drive Control Interfaces and Priority Control Modules Inside ZEDB Component Boundaries

#### **7 References**

##### **Data Tables**

##### **A Valves**

- A.1 Check Valves
  - A.1.1 Lift Check Valve, Nominal Size > 50
  - A.1.2 Lift Check Valve, Nominal Size ≤ 50
  - A.1.3 Swing Check Valve
  - A.1.4 Lift Check Valve, Lockable in Closed Position
  - A.1.5 Swing Check Valve for Essential Service Water, Nominal Size ≥ 250
  - A.1.6 Swing Check Valve for Essential Service Water, Nominal Size < 250
  - A.1.7 Lift Check Valve with external motor for opening
  - A.1.8 Lift Check Valve with Locking Piston for Closure
- A.2 Motor-Operated Isolation Valves
  - A.2.1 Main Steam Relief Isolation Valve
  - A.2.2 Feedwater Isolation Valve - Main Valve
  - A.2.3 Reactor Water Cleanup System Containment Isolation Valve
  - A.2.4 Isolation Valves of Small Nominal Size
  - A.2.5 Isolation Valves of Medium Nominal Size
  - A.2.6 PWR Sump Valve
  - A.2.7 Isolation Valves of Large Nominal Size
  - A.2.8 Pressurizer Relief Isolation Valve

- A.3 System-Fluid-Operated Isolation Valves
  - A.3.1 PWR Main Steam Isolation Valve
  - A.3.2 BWR Main Steam Isolation Valve
  - A.3.3 Turbine Stop Valve
  - A.3.4 Main Steam Relief Isolation Valve
  - A.3.5 Main Steam Isolation and Safety Valve within the Containment
- A.4 Motor-Operated Gate valves
  - A.4.1 Main Steam Containment Isolation Valve
  - A.4.2 Main Steam Relief Isolation Valve
  - A.4.3 Feedwater Isolation Valve - Main Valve
  - A.4.4 Feedwater Isolation Valve - Startup and Emergency Feedwater
  - A.4.5 BWR Emergency Core Cooling and Residual Heat Removal System Isolation Valve
  - A.4.6 BWR Emergency Core Cooling and Residual Heat Removal System Isolation Valve Connected to Main Steam Piping
  - A.4.7 Isolation Valve for Volume Control, Residual Heat Removal, Extra Borating and Emergency Feedwater Systems
  - A.4.8 Steam Generator Blowdown Isolation Valve
  - A.4.9 Demineralized Water Supply System Isolation Valve of Medium, Nominal Size
- A.5 System-Fluid-Operated Gate valves
  - A.5.1 Main Steam Isolation Valve
- A.6 Motor-Operated Shutoff Valves
  - A.6.1 Nuclear Component Cooling Water Shutoff Valve
  - A.6.2 Essential Service Water Shutoff Valve
  - A.6.3 Essential Service Water Shutoff Valve, Nominal Size < 250
- A.7 Hydraulically Operated Shutoff Valves
  - A.7.1 Nuclear Component Cooling Water Quick-Closing Shutoff Valve
- A.8 Control Valves
  - A.8.1 Main Steam Relief Control Valve
  - A.8.2 Feedwater Control Valve - Main Valve
  - A.8.3 Control Valve for Startup Feedwater, Emergency Feedwater and Emergency Feedwater Pressure Control
  - A.8.4 Demineralized Water Makeup Control Valve
  - A.8.5 Residual Heat Removal Control Valve
  - A.8.6 Feedwater Control Valve - Startup
  - A.8.7 Emergency Feedwater Control Valve - Pressure Control
  - A.8.8 Emergency Feedwater Control Valve
  - A.8.9 High-Pressure Reducing Station Control Valve
  - A.8.10 Boric Acid Control Valve Chemical Control System
  - A.8.11 Demineralized Water Control Valve Chemical Control System
- A.9 Motor-Operated Multiport Valves
  - A.9.1 PWR Sump Valve
  - A.9.2 Three-Way Valve for Residual Heat Removal / Fuel Pool Suction Line
  - A.9.3 Three-Way Valve for Pressurizer Auxiliary Spraying from Volume Control System
  - A.9.4 Three-Way Valve for Pressurizer Auxiliary Spraying from Extra Borating System

## Centralized Reliability and Events Database

### Reliability Data for Nuclear Power Plant Components

(Basis edition and enclosed 1st and 2nd upgrading)

#### Contents *(continued)*

<ul style="list-style-type: none"> <li>A.10 System-Fluid-Operated Multiport Valves</li> <li>A.10.1 High-Pressure Coolant Injection Valve</li> <li>A.11 Safety Valves</li> <li>A.11.1 Main Steam Safety Valve</li> <li>A.11.2 Safety-Relief Valve</li> <li>A.11.3 Pressurizer Relief Valve</li> <li>A.11.4 Pressurizer Safety Valve</li> <li>A.12 Heating, Ventilation and Air-Conditioning (HVAC) Valves</li> <li>A.12.1 HVAC Containment Isolation Valve</li> <li>A.12.2 HVAC Containment Isolation Damper</li> <li>A.13 Pilot Valves of Globe, Shutoff Valve Type</li> <li>A.13.1 Spring-Loaded Pilot Valve for Pressurizer Valves</li> <li>A.13.2 Spring-Loaded Pilot Valve for Main Steam Valves</li> <li>A.13.3 Spring-Loaded Pilot Valve for Safety-Relief Valves</li> <li>A.13.4 Solenoid Pilot Valve for Pressurizer Relief Valves</li> <li>A.13.5 Solenoid Pilot Valve for Main Steam Valves</li> <li>A.13.6 Normally Deenergized Solenoid Pilot Valve for Main Steam Valves</li> <li>A.13.7 Normally Energized Solenoid Pilot Valve for Main Steam Valves</li> <li>A.13.8 Solenoid Pilot Valve for Safety-Relief Valves</li> <li>A.13.9 Solenoid Pilot Valve for Demineralized Water</li> <li>A.13.10 Air-Operated Pilot Valve</li> <li>A.13.11 Motor-Operated Pilot Valve for Pressurizer Relief Valve and Pressurizer Safety Valve</li> <li>A.13.12 Motor-Operated Pilot Valve for Main Steam Valves</li> <li>A.14 Pilot Valves of Multiport Valve Type</li> <li>A.14.1 Solenoid Pilot Valve for Air</li> <li>A.14.2 Solenoid Pilot Valve for Oil</li> <li>A.14.3 Solenoid Pilot Valve for HVAC Containment Isolation Dampers</li> <li>A.15 Manually actuated valves</li> <li>A.15.1 Manually Actuated Butterfly Valve for Demineralized or Borated Water, Nominal Size <math>\leq 50</math></li> <li>A.15.2 Manually Actuated Butterfly Valve for Demineralized or Borated Water, <math>200 \leq</math> Nominal Size <math>\leq 400</math></li> <li>A.15.3 Manually Actuated Butterfly Valve for Demineralized or Borated Water, Nominal Size <math>&gt; 400</math></li> <li>A.15.4 Manually Actuated Gate Valve for Demineralized or Borated Water, <math>50 \leq</math> Nominal Size <math>\leq 125</math></li> <li>A.15.5 Manually Actuated Gate Valve for Demineralized or Borated Water, <math>125 \leq</math> Nominal Size <math>\leq 250</math></li> <li>A.15.6 Manually Actuated Gate Valve for Demineralized or Borated Water, Nominal Size <math>&gt; 250</math></li> <li>A.15.7 Manually Actuated Gate Valve for Water, <math>50 \leq</math> Nominal Size <math>\leq 125</math></li> <li>A.15.8 Manually Actuated Gate Valve for Water, <math>125 \leq</math> Nominal Size <math>\leq 250</math></li> <li>A.15.9 Manually Actuated Isolation Valve for Demineralized or Borated Water, Nominal Size <math>\leq 50</math></li> <li>A.15.10 Manually Actuated Isolation Valve for Demineralized or Borated Water, <math>50 \leq</math> Nominal Size <math>\leq 200</math></li> <li>A.15.11 Manually Actuated Isolation Valve for Demineralized or Borated Water, Nominal Size <math>&gt; 200</math></li> </ul>	<ul style="list-style-type: none"> <li><b>B Pumps</b></li> <li>B.1 Motor-Driven Centrifugal Pumps</li> <li>B.1.1 Fluid Pumped: Demineralized or Borated Water</li> <li>B.1.1.1 Pump Group Population 1</li> <li>B.1.1.2 Pump Group Population 2</li> <li>B.1.1.3 Pump Group Population 3</li> <li>B.1.1.4 Pump Group Population 4</li> <li>B.1.1.5 Pump Group Population 5</li> <li>B.1.1.6 Pump Group Population 6</li> <li>B.1.1.7 High-Pressure Charging Pump</li> <li>B.1.1.8 Control Rod Drive Pump</li> <li>B.1.1.9 Startup / Shutdown Pump</li> <li>B.1.1.10 High-Pressure Safety Injection Pump</li> <li>B.1.1.11 Makeup Pump</li> <li>B.1.1.12 Canned Motor Pump</li> <li>B.1.1.13 Fuel Pool Cooling Pump</li> <li>B.1.1.14 Emergency Residual Heat Removal Pump (BWR)</li> <li>B.1.1.15 Residual Heat Removal Pump (PWR)</li> <li>B.1.1.16 Residual Heat Removal Pump (BWR)</li> <li>B.1.1.17 Flooding Pump</li> <li>B.1.1.18 Emergency Component Cooling Water Pump (PWR)</li> <li>B.1.1.19 Component Cooling Water Pump (PWR / BWR)</li> <li>B.1.1.20 Nuclear Component Cooling Water Pump</li> <li>B.1.1.21 Secured Closed Cooling Water Pump</li> <li>B.1.1.22 Main Condensate Pump</li> <li>B.1.1.23 Main Feedwater Pump</li> <li>B.1.2 Fluid Pumped: Normal Water</li> <li>B.1.2.1 Pump Group Population 7</li> <li>B.1.2.2 Pump Group Population 8</li> <li>B.1.2.3 Pump Group Population 9</li> <li>B.1.2.4 Pump Group Population 10</li> <li>B.1.2.5 Well Pump</li> <li>B.1.2.6 Emergency Service Water Pump</li> <li>B.1.2.7 Service Water Pump</li> <li>B.2 Diesel-Driven Centrifugal Pumps</li> <li>B.2.1 Fluid Pumped: Demineralized or Borated Water</li> <li>B.2.1.1 Safety Injection Pump</li> <li>B.2.1.2 Emergency Feedwater Pump</li> <li>B.3 Turbine-Driven Centrifugal Pumps</li> <li>B.3.1 Fluid Pumped: Demineralized or Borated Water</li> <li>B.3.1.1 Coolant Injection Pump</li> <li>B.3.1.2 Emergency Feedwater Pump</li> <li>B.4 Motor-Driven Reciprocating Pumps</li> <li>B.4.1 Fluid Pumped: Borated Water</li> <li>B.4.1.1 Boron Injection Pump</li> <li>B.5 Motor-Driven Diaphragm Pumps</li> <li>B.5.1 Fluid Pumped: Demineralized Water</li> <li>B.5.1.1 Seal Water Pump</li> <li>B.6 Motor-Driven Gear Pumps</li> <li>B.6.1 Fluid Pumped: Oil</li> <li>B.6.1.1 Oil Pump</li> </ul>
--	---

## Centralized Reliability and Events Database

### Reliability Data for Nuclear Power Plant Components

(Basis edition and enclosed 1st and 2nd upgrading)

#### Contents *(continued)*

<b>C</b>	<b>Fans</b>	<b>J</b>	<b>Static Converters</b>
C.1	Fans of 0.11 - 4 kW Capacity	J.1	24V Rectifiers
C.2	Fans of 5.5 - 45 kW Capacity	J.2	220V Rectifiers
C.3	Fans of 55 - 145 kW Capacity	J.3	220V Inverters
<b>D</b>	<b>Emergency Diesel Generators</b>	J.4	400V Inverters
D.1	Emergency Diesel Generators of 320 - 1740 kW Capacity	<b>K</b>	<b>Transformers</b>
D.2	Emergency Diesel Generators of 2682 - 5000 kW Capacity	K.1	Generator Transformers
<b>E</b>	<b>Vessels / Tanks</b>	K.2	Three-Winding Standby Offsite Power System Transformers
E.1	Scram Accumulators	K.3	Two-Winding Standby Offsite Power System Transformers
E.2	Refueling Water Storage Tanks	K.4	Three-Winding Auxiliary Power Transformers
E.3	Common Scram Tanks	K.5	Two-Winding Low-Voltage Transformers
E.4	Single Scram Tanks	K.6	Three-Winding Low-Voltage Transformers
E.5	Nitrogen Tanks for Single Scram Tanks	K.7	Two-Winding Low-Voltage Transformers
<b>F</b>	<b>Heat Exchangers</b>	K.8	Two-Winding Voltage Stabilizers
F.1	Residual Heat Removal Heat Exchangers	<b>L</b>	<b>Busbars</b>
F.2	Nuclear Component Closed Cooling Water Heat Exchangers	L.1	20 - 30kV AC Busbars
<b>G</b>	<b>Control Rods</b>	L.2	6 - 10.5kV AC Busbars
G.1	PWR Control Rods	L.3	400 - 660V AC Busbars
G.2	BWR Control Rods	L.4	220V DC Busbars
<b>H</b>	<b>Batteries</b>	L.5	24 - 48V DC Busbars
H.1	Batteries Rated for 24 - 48 V	<b>M</b>	<b>Circuit Breakers</b>
H.2	Batteries Rated for 220 V	M.1	20 - 30kV Generator Breakers
<b>I</b>	<b>Rotating Inverters</b>	M.2	6 - 10.5kV Circuit Breakers
I.1	Rotating Inverters	M.3	400 - 660V Circuit Breakers
		M.4	400 - 660V Load Breakers
		M.5	220V Load Breakers
		M.6	24 - 48V Load Breakers

<b>Imprint</b>	Published by:	VGB PowerTech e.V. ISSN 2191-9534
	Available from:	VGB PowerTech Service GmbH Verlag technisch-wissenschaftlicher Schriften P.O. Box 10 39 32, 45039 Essen, Germany
	Price:	999 EUR (+ postage and VAT)

---

<u>Contact:</u>	André Seidel VGB PowerTech e. V. Kernkraftwerke Klinkenstr. 27 – 31 45136 Essen Germany Phone: +49 (0) 2 01 81 28-291 Fax: +49 (0) 2 01 81 28-345 Mail: andre.seidel@vgb.org	Jürgen Zimander VGB PowerTech Service GmbH Verlag technisch-wissenschaftlicher Schriften P.O. Box 10 39 32 45039 Essen Germany Phone: +49 (0) 2 01 81 28-200 Fax: +49 (0) 2 01 81 28-329 Mail: mark@vgb.org
-----------------	--	---